

**Himachal Pradesh Public Works Department**

No.PWU/CB/WA/ B-6/2020-21

17862-63 Dated:- 10-3-2021

To,


The Principal,  
A.N.M International School  
VPO Tahliwal  
Tehsil Haroli Distt. Una (H.P)

**Subject: - Regarding issue of Building safety Certificate 2021-22.**


In this connection, it is intimated that the subject cited building of A.N.M International School situated at Village Tahliwal Tehsil Haroli Distt.Una, has been visited & inspected by the concerned Assistant Engineer on dated 18.2.2021. At the time of inspection it has been found that structural drawings were not got approved from the competent Govt. certified engineer. Moreover no any kinds of technical assistance has been taken from PWD authorities during the construction of the building. It is therefore, the structural safety of this building may not be ensured specifically from earthquake resistance point of view. Hence this department would not be held responsible for any type of loss of life and property etc, if this structure fails under any unforeseen circumstances.

However as per the visual inspection it has been observed that the existing building as per the drawings produced during inspection seems to be safe at present under normal circumstances only for the year 2021-22. No Officer/ official of this department would attend any plea in any Hon;ble Court of law for any type of dispute and claim and loss.

This certificate is only for official use and not for legal purpose

  
**Executive Engineer,  
Una Division, HP.PWD,  
Una.**

Copy to the Assistant Engineer, T/wala Sub-Division HP,PWD Haroli for information with reference to his office letter No. 2286 Dated 18.2.2021

  
**Executive Engineer,  
Una Division, HP.PWD.,  
Una**

  
**Principal  
ANM International School  
Tahliwal, Distt. Una (H.P.)**